



Ref. Certif. No.

**SG SGS-00425****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEME****CB TEST CERTIFICATE**

Product

Rechargeable Li-ion battery system

Name and address of the applicant

Sunwoda Energy Technology Co., Ltd.  
Room 201, Building C, Sunwoda Electronic Factory, Tangjia Community,  
Fenghuang Street, Guangming District, Shenzhen, 518107, Guangdong,  
China

Name and address of the manufacturer

Sunwoda Energy Technology Co., Ltd.  
Room 201, Building C, Sunwoda Electronic Factory, Tangjia Community,  
Fenghuang Street, Guangming District, Shenzhen, 518107, Guangdong,  
China

Name and address of the factory

Note: When more than one factory, please report on page 2

Huizhou Sunwoda Energy Technology Co., Ltd.  
Zhenghao Industrial Park, Jiweidu, Zhenxing street, Yuanzhou  
Town, Boluo County, Huizhou, Guangdong, China

Ratings and principal characteristics

NoahX-L43, Oasis-L43, Noah-154/43-L: 153.6 Vdc, 280 Ah  
NoahX-L86, Oasis-L86, Noah-307/86-L: 307.2 Vdc, 280 Ah  
NoahX-L129, Oasis-L129, Noah-460/129-L: 460.8 Vdc, 280 Ah  
NoahX-L172, Oasis-L172, Noah-614/172-L: 614.4 Vdc, 280 Ah  
NoahX-L215, Oasis-L215, Noah-768/215-L: 768 Vdc, 280 Ah  
NoahX-L258, Oasis-L258, Noah-912/258-L: 912.6 Vdc, 280 Ah  
NoahX-L301, Oasis-L301, Noah-1075/301-L: 1075.2 Vdc, 280 Ah  
NoahX-L344, Oasis-L344, Noah-1500/344-L: 1228.8 Vdc, 280 Ah  
Battery module: Rated Voltage: 153.6 Vdc, Rated Capacity: 280 Ah

Trademark / Brand (if any)

SUNWODA

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

NoahX-L43, Oasis-L43, Noah-154/43-L, NoahX-L86, Oasis-L86,  
Noah-307/86-L, NoahX-L129, Oasis-L129, Noah-460/129-L, NoahX-L172,  
Oasis-L172, Noah-614/172-L, NoahX-L215, Oasis-L215, Noah-768/215-L,  
NoahX-L258, Oasis-L258, Noah-912/258-L, NoahX-L301, Oasis-L301,  
Noah-1075/301-L, NoahX-L344, Oasis-L344, Noah-1500/344-L  
Battery module: B1F-154/43-CN

Additional information (if necessary may also be reported on page 2)

-

National Differences:  
EU Group Differences, GB

A sample of the product was tested and found to be in conformity with


IEC 62619:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

CQES240800073101

This CB Test Certificate is issued by the National Certification Body

SGS Testing & Control Services Singapore Pte Ltd  
30 Boon Lay Way  
#03-01 Singapore 609957

Jacob Lu 

Date: 20/08/2024

Signature:

Jacob Lu  
Certifier